

Energy performance certificate (EPC)

2, Llanina Grove
Rumney
CARDIFF
CF3 1SW

Energy rating

D

Valid until: 29 October 2025

Certificate number: 7708-2997-7270-3385-9930

Property type Semi-detached house

Total floor area 88 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Energy rating and score

This property's energy rating is D. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		77 C
55-68	D	58 D	
39-54	E		
21-38	F		
1-20	G		

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	System built, as built, no insulation (assumed)	Very poor
Roof	Pitched, 300 mm loft insulation	Very good
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Good
Lighting	Low energy lighting in 30% of fixed outlets	Average
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, mains gas	N/A

Primary energy use

The primary energy use for this property per year is 286 kilowatt hours per square metre (kWh/m²).

Additional information

Additional information about this property:

- System build present
-

How this affects your energy bills

An average household would need to spend **£1,016 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £218 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2015** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 11,364 kWh per year for heating
- 2,174 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is E. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces 6 tonnes of CO₂

This property produces 4.4 tonnes of CO₂

This property's potential production 2.4 tonnes of CO₂

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Floor insulation (solid floor)	£4,000 - £6,000	£38
2. Low energy lighting	£35	£33
3. Heating controls (room thermostat)	£350 - £450	£41
4. Condensing boiler	£2,200 - £3,000	£80
5. Flue gas heat recovery	£400 - £900	£27

Step	Typical installation cost	Typical yearly saving
6. Solar photovoltaic panels	£5,000 - £8,000	£290

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Lawrence Griffiths
Telephone	01685815805
Email	lawrencegriffiths@rocketmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Sterling Accreditation Ltd
Assessor's ID	STER450051
Telephone	0161 727 4303
Email	info@sterlingaccreditation.com

About this assessment

Assessor's declaration	No related party
Date of assessment	30 October 2015
Date of certificate	30 October 2015
Type of assessment	RdSAP
